



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131453, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Wednesday, November 27, 2013

Partial Correction

1 MISC

FASTENER PATTERN EXTERIOR AT WALL SHEATHING FROM FF ELEVATION TO 9' ABOVE FF MEETS OR EXCEEDS INDUSTRY STANDARDS (NO SPEC FOUND ON DRAWINGS). OK TO COVER ENTIRE HEIGHT OF ROOF WHEN READY.

Comments: