

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20131761  
**Address:** 2000 SE BLUE PKWY, LEES SUMMIT, MO 64063  
**Inspected On:** Monday, December 02, 2013  
**Inspected By:** Mike CopelandJoe DirJoe Dir  
**Expiration Date:** 1/10/2014 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection:                                    | Inspector:    | Outcome:         | Date:                     |
|--|---------------|------------------|---------------------------|
| <b>Occupancy Inspection - Codes Commercial</b> | Mike Copeland | Temporary C of O | Monday, December 02, 2013 |

**Corrective Action Required:**

|   |      |   |
|---|------|---|
| 1 | MISC | OBTAIN FIRE DEPARTMENT APPROVAL BY TESTING GENERATOR. |
|---|------|---|

|                   |         |        |                           |
|-------------------|---------|--------|---------------------------|
| <b>Alarm Test</b> | Joe Dir | Passed | Monday, December 02, 2013 |
|-------------------|---------|--------|---------------------------|

|                                    |         |                  |                           |
|------------------------------------|---------|------------------|---------------------------|
| <b>Occupancy Inspection - Fire</b> | Joe Dir | Temporary C of O | Monday, December 02, 2013 |
|------------------------------------|---------|------------------|---------------------------|

**Corrective Action Required:**

|   |      |   |
|---|------|---|
| 1 | MISC | -Hospital will be supplying the suite addressing for off the corridor<br>- Emergency generator power test will be conducted later in December, written conformation will be supplied by elec contractor of results of test. |
|---|------|---|

-alarm plans will be supplied by Seimens