

PLAN REVIEW CONDITIONS

December 02, 2013

TEAGUE CONSTRUCTION INC
4220 MAIN ST
GRANDVIEW, MO 64030

Permit No: PRCOM20131937
Project Title: CARESPOT EXPRESS HEALTHCARE
Project Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Parcel Number: 62140031600000000
Location: SUMMIT SHOPPING CENTER LOT 1
Type of Work: NEW TENANT FINISH
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR NEW URGENT CARE FACILITY TREATING ILLNESS, LACERATIONS, BROKEN BONES ETC.

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

Fire Plan Review

Reviewed By: Brian Austerman

Approved with Conditions

1. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Provide addressing, verified at inspection

2. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of a 2A10B:C extinguisher for every 3,000 sq/ft or for every 75' of travel distance. Verified at inspection

- _____ Approved to issue per the listed conditions.
- _____ Do not issue per the listed conditions.
- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

_____	_____
Signature of Applicant	Date

_____	_____
Print Applicant Name	CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.