



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Tuesday, December 03, 2013
Underground Plumbing Inspection - Commercial	John Borns	Passed	Tuesday, December 03, 2013

Comments: OK TO COVER WHEN READY 4" PVC SANITARY DRAIN PIPING CONNECTING BUILDING DRAIN TO SANITARY SEWER SERVICE LINE OUTSIDE AREA "A" BUILDING CORNER NEAR F.8/13.