



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131453, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Tuesday, December 03, 2013

Partial Correction
1 MISC

NO ISSUES FOUND ON TRENCHING AND PLACEMENT OF 4" PVC CONDUIT FOR ELECTRICAL SECONDARY FEEDER FROM NORTH EDGE OF PERIMETER OF FREDDIE'S RESTAURANT CONSTRUCTION FENCE TO 90' NORTH TOWARD THIS BUILDING;

NOTE: NO CONDUIT SIZES, SPECIFICS NOR SPECIFICATIONS FOUND ON DRAWINGS.

Comments: