



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20132180, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, December 04, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY COMPONENTS OF RATED MECHANICAL SHAFTS:
> SHAFT AT B'.2/18.5: FRAMING AND INNER LAYER SHAFT LINER BOARD OK TO COMPLETE AND FIRE-SEAL

Partial Correction
2 MISC

GWB AT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, & FIRE-SEAL WHEN READY 5/8" TYPE X GWB INSTALLATION @ FOLLOWING LOCATIONS: **SPACE 136 S WALL 4' TOP-OUT;**

Comments: