



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20131163, Building Permit - Residential

Address: 610 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081610 NW REDBUD DR,
Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

Footing Inspection - Khanh Nguyen Passed
Residential

Wednesday, December 04, 2013

Comments:

FOOTING PER PLAN. UFER GROUNDING ELECTRODES ARE LOCATED AT REAR F.
WALL CORNER NEAR PARTY WALL