



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20132126, Building Permit - Commercial
Address: 2301 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Friday, December 06, 2013

Corrective Action Required
1 MISC

- COMPLETE IN-WALL BLOCKING FOR RESTROOM GRAB BARS
- DRAINAGE LINE FROM 2ND FL BREAK RM SINK-MINIMUM 1/4" PER FOOT SLOPE REQUIRED
- PROTECT PVC WHERE WITHIN 1.5" OF THE STUD/TRACK SURFACE
- COMPLETE WALL FRAMING OF THE 2ND FL BREAK RM

Comments: