

CITY OF LEE'S SUMMIT CODES ADMINISTRATION

220 SE GREEN ST. P.O.BOX 1600 PHONE: 816-969-1200

FAX: 816-969-1201

Certificate of Occupancy

Permit #: PRRES20122126

Address: 301 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

Inspected On: Thursday, December 12, 2013

Inspected By: John Borns

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy John Borns Full C of O Thursday, December 12, 2013

Inspection - Codes

Residential

Comments: CAUTION TO PERMIT HOLDER / HOMEOWNER: INDUSTRY STANDARD MANUFACTURER INSTRUCTIONS REQUIRE MOUNTING HEIGHT OF CEILING FANS PROVIDE MINIMUM 7' FLOOR-TO-BLADES CLEARANCE; LOWER INSTALLATION COULD RESULT IN PERSONAL INJURY.