



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131453, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------|------------|----------|---------------------------|
| In-wall Inspection | John Borns | Failed | Friday, December 13, 2013 |

Corrective Action Required

| | | |
|---|------|---|
| 1 | MISC | INSTALL ONE ANCHOR BOLT WITHIN 12" MAX OF ENDS OF BOTTOM PLATE SEGMENTS |
|---|------|---|

Corrective Action Required

| | | |
|---|------|--|
| 2 | MISC | FULLY BOLT BASE PLATES OF STEEL PIPE COLUMNS |
|---|------|--|

Corrective Action Required

| | | |
|---|------|--------------------------------|
| 3 | MISC | ENSURE ALL A.B. NUTS ARE TIGHT |
|---|------|--------------------------------|

Comments: