



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20132239, Building Permit - Commercial
Address: 3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Monday, December 16, 2013

Partial Correction
1 MISC

-FOOTING OK AS PROGRESSED: EXTERIOR GRADE BEAM COMPLETED, EXCEPT AT THE SE CORNER

Corrective Action Required
3 MISC

OK TO POUR WHEN READY ISOLATED FOOTINGS AT FOLLOWING LOCATIONS: ALL AT LOBBY AREA EXCLUDING THOSE INTEGRAL WITH EXTERIOR WALL AND ELEVATOR PIT SLAB; 3x3 SHEAR WALL HOLD-DOWN FOOTINGS AT N-S AND E-W WINGS;

Footing Inspection - Commercial	John Borns	Not Ready	Monday, December 16, 2013
--	------------	-----------	---------------------------

Partial Correction
1 MISC

-FOOTING OK AS PROGRESSED: EXTERIOR GRADE BEAM COMPLETED, EXCEPT AT THE SE CORNER

Corrective Action Required
3 MISC

"READY AT 9:30" NOT READY AT 9:50. NO PERMIT PRINTS ON SITE.

Comments: