

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

December 17, 2013

JE DUNN CONSTRUCTION 1001 LOCUST KANSAS CITY, MO 64106

Permit No:	PRCOM20132665
Project Title:	SAINT LUKE'S EAST
Project Address:	100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Parcel Number:	5244004400000000
Location:	SAINT LUKES HOSPITAL OF LEES SUMMIT LOTS 1 & 2LOT 1
Type of Work:	ALTERATION COMMERCIAL
Occupancy Group:	MIXED OCCUPANCY
Description:	KITCHEN/DINING EXPANSION - TEMP KITCHEN

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200		Fire Department (816) 969-1300	
Licensed Contractors		Reviewed By: Michael Weisenborn	Approved
Building Plan Review		Reviewed By: Michael Weisenborn	Approved with Conditions

1. 2006 IPC - Section 608.16.10 - Coffee machines and noncarbonated beverage dispensers. The water supply connection to coffee machines and noncarbonated beverage dispensers shall be protected against backflow by a backflow preventer conforming to ASSE 1022 or by an air gap.

Action required - This comment is for information purposes and compliance will be verified on inspection.

Reviewed By: Brian Austerman

Approved with Conditions

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Provide sprinkler plans if alterations are made to the sprinkler system

2. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1200

and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide plans for any alterations to the alarm system

- _____ Approved to issue per the listed conditions.
- _____ Do not issue per the listed conditions.
- _____ Approved to construct foundation only per the listed conditions.
- _____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant	Date	
Print Applicant Name	CompanyName	

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.