



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20132239, Building Permit - Commercial
Address: 3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	John Borns	Partial	Wednesday, December 18, 2013

Partial Correction

1 MISC

-FOOTING OK AS PROGRESSED: EXTERIOR GRADE BEAM COMPLETED, EXCEPT AT THE SE CORNER

Partial Correction

2 MISC

OK TO POUR WHEN READY ISOLATED FOOTINGS AT FOLLOWING LOCATIONS: ALL AT LOBBY AREA EXCLUDING THOSE INTEGRAL WITH EXTERIOR WALL AND ELEVATOR PIT SLAB; 3x3 SHEAR WALL HOLD-DOWN FOOTINGS AT N-S AND E-W WINGS;

Partial Correction

4 MISC

ELEVATOR PIT SLAB OK TO POUR WHEN READY

Foundation Inspection - Commercial	John Borns	Not Ready	Wednesday, December 18, 2013
---	------------	-----------	------------------------------

Partial Correction

1 MISC

-FOOTING OK AS PROGRESSED: EXTERIOR GRADE BEAM COMPLETED, EXCEPT AT THE SE CORNER

Partial Correction

2 MISC

OK TO POUR WHEN READY ISOLATED FOOTINGS AT FOLLOWING LOCATIONS: ALL AT LOBBY AREA EXCLUDING THOSE INTEGRAL WITH EXTERIOR WALL AND ELEVATOR PIT SLAB; 3x3 SHEAR WALL HOLD-DOWN FOOTINGS AT N-S AND E-W WINGS;

Partial Correction
3 MISC

NOT READY AS OF 10:35

Comments: