



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20132126	Date:	December 18, 2013
Project Title:	SUBTECHNOLOGY	Applicant:	
Location:	2301 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064		ALARMS BY STERLING SECURITY 310 E 125TH TERRACE KANSAS CITY, MO 64145
Type of Work:			
Occupancy Group:	MIX		
Description:	CHANGE OF TENANT		
Construction Type:	Type IIB (Unprotected)	Primary:	(816) 942-3110
Map Page:	175V		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 2006 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

Call 816-969-1300 to schedule alarm testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.