



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131453, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Commercial	John Borns	Not Ready	Thursday, December 19, 2013

Partial Correction

1 MISC

SERVICE OK TO COVER AT SOURCE END; MIDDLE SECTION
WAS DIRECTIONAL-BORED; BUILDING END NOT READY --
COVERED WITH CRUSHED ROCK.

Sewer Service Inspection - Commercial	John Borns	Passed	Thursday, December 19, 2013
--	------------	--------	-----------------------------

Comments: OK TO COVER WHEN READY INITIAL PARTIAL SANITARY SEWER SERVICE
INSTALL FROM BUILDING ENTRY TO 50' SW; **OK TO COVER WHEN READY FINAL
PARTIAL SEWER SERVICE INSTALLATION COMPLETE & CONNECTED TO PRIVATE
MAIN.**