



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131453, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Friday, December 20, 2013

Corrective Action Required

1 MISC

SECURE RISER INSIDE EAST EXTERIOR WALL

Corrective Action Required

2 MISC

COMPLETE PIPE SUPPORT BLOCKS PER IFGC AT ROOFTOP

Corrective Action Required

3 MISC

IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS. SEE GAS PIPING AT METER AND ROOFTOP.

Gas Service Inspection - Commercial	John Borns	Passed	Friday, December 20, 2013
--	------------	--------	---------------------------

In-wall Inspection	John Borns	Partial	Friday, December 20, 2013
---------------------------	------------	---------	---------------------------

Corrective Action Required

4

**OK TO COVER WHEN READY WALL FRAMING + IN-WALL
SYSTEMS AT FOLLOWING SPACES: EXTERIOR WALLS;**

Comments: GAS PIPING PRESSURE TEST HELD STEADY AT ≥ 10 PSI FOR ≥ 10 MIN.

RELEASE GAS SERVICE.