



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130305, Building Permit - Commercial  
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Friday, December 20, 2013

Corrective Action Required  
1 MISC

SPACES TO RECEIVE PROPRIETARY CEILING NOT READY FOR ABOVE-CEILING INSPECTION: B107; B123; B125; B127; B133; B134; B107

Partial Correction  
2 MISC

OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: B101; B110; B115; B116; B120;

Partial Correction  
3 MISC

**AREAS TO RECEIVE SECURITY TILE CEILING OK TO PLACE CRITICAL TILE: 104; 106; 112; 126; 119;**

**Sprinkler - Hydrostatic Test**

Joe Dir

Partial

Friday, December 20, 2013

**Comments:**