

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20132504, Building Permit - Commercial Address: 1479 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Mark Harding Passed Friday, December 20, 2013

Inspection - Commercial

Corrective Action Required

1 MISC -MAKE UP JUNCTION BOXES

-SECURE MC WITHIN 6 INCHES OF THE BOX

Comments: