



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131937, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Not Ready	Monday, December 30, 2013

Corrective Action Required
1 MISC

INSTALLATION, INSIDE AND OUTSIDE, DOES NOT REFLECT
APPROVED DRAWINGS. UFER GROUND NOT FOUND INSTALLED.

Comments: