



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Monday, December 30, 2013

Partial Correction
2 MISC

OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: B101; B110; B115; B116; B120;

Partial Correction
4 MISC

ABOVE-CEILING SYSTEMS APPROVED WITH CONDITIONS STATED BELOW AT FOLLOWING SPACES WITH SECURITY CEILING SYSTEM INSTALLED: **104; 105; 106; 107; 108; 111; 114; 114a; 118; 123; 125; 127; 128; 130; 133; 134**

ENSURE ACOUSTICAL INSULATION WHERE REQUIRED IS COMPLETELY INSTALLED AND IN PROPER LOCATION BEFORE OCCUPANCY. TEMPORARY ELECTRICAL WIRING TO BE REMOVED. ALSO REMOVE ALL SCRAP MC ELECTRICAL CABLE AND OTHER DEBRIS.

Comments: