



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130393, Building Permit - Commercial
Address: 194 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	John Borns	Partial	Friday, January 03, 2014

Partial Correction

1 MISC

IF LAYOUT IS CORRECT FOR CONCENTRIC LOADING OK TO POUR WHEN READY 4 MENU BOARD PIERS PER 8-1/2" X 11" DRAWINGS ON SITE. ENSURE 3" RE-BAR COVERAGE AT BOTTOMS AND BANKS AND ANCHOR BOLT PLACEMENT PER DRAWINGS.

Comments: