



LEE'S SUMMIT MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20130422	Date:	January 06, 2014
Project Title:	WILSHIRE HILLS II	Applicant:	
Location:	3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064	NATIONAL FIRE SUPPRESSION INC	
Type of Work:		501 SUNSHINE ROAD	
Occupancy Group:	R-2	KANSAS CITY, KS 66115--1294	
Description:	3-STORY SENIOR LIVING		
Construction Type:	Type VA (1 hour)	Primary:	(913) 321-9208
Map Page:	175L		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Plans released for construction as per resubmittal showing backflow device on antifreeze loop and check valve on riser.
2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call 816-969-1300 to schedule hydrostatic and flow testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.