



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20132504, Building Permit - Commercial
Address: 1479 SW MARKET ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Failed	Monday, January 06, 2014

Corrective Action Required
1 MISC

- INSTALL COMBUSTION AIR OPENINGS FOR MECHANICAL ROOM 24x6 WITHIN 12 INCHES FROM THE BOTTOM OF THE ROOM AND 12" INCHES FROM THE TOP
- REPAIR LIGHT NORTH SIDE OF MULTI PURPOSE ROOM
- POST OCCUPANT LOAD AT ENTRANCE TO MULTI PURPOSE ASSEMBLY AREA

Comments: