



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRRES20132088, Building Permit - Residential  
Address: 1316 NE ERNEST WAY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Khanh Nguyen	Passed	Thursday, January 09, 2014

<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, January 09, 2014
---	--------------	--------	----------------------------

Corrective Action Required  
1 MISC

- NAIL GARAGE PORTAL BRACE WALL SHEATHING PER CODE
- NAIL REAR EXTERIOR WALL SIDING TO SILL
- NAIL CORNER STUDS AT REAR DINING WALL
- BLOCK THE DECK DOOR STUDS TO CORNERS AT STRIKE PLATE HEIGHT
- FIREBLOCKING: REAR DUCT/PLUMBING SPACE (FB GAP); FB VERTICAL SPACES AT KITCHEN/GARAGE WALL FROM HORIZONTAL SPACE; FB GARAGE DUCT/PLUMBING SPACE FROM ROOF AND SOFFIT
- INSTALL BOOT FLASHING FOR 3" VENT
- INSTALL BOCA PLATE AT BATH/LAUNDRY WALL TOP PLATE

\*\*OK TO INSULATE. NO ROCK

**Comments:**

