



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20131453, Building Permit - Commercial  
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Passed	Friday, January 10, 2014
<b>Miscellaneous Inspection</b>	John Borns	Passed	Friday, January 10, 2014

**Comments: EXTERIOR WALL FRAMING AND IN-WALL SYSTEMS OK TO COVER WHEN READY.**