



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRRES20131169, Building Permit - Residential

Address: 600 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081600 NW LILAC PL, Unit:C,  
LEES SUMMIT, MO 64081600 NW LILAC PL, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	John Borns	Partial	Monday, January 13, 2014

Partial Correction  
1 MISC

GAS PIPING PRESSURE TEST HELD STEADY AT  $\geq 10$  PSI FOR  
 $\geq 10$  MIN. RELEASE GAS SERVICE FOLLOWING UNIT: **A**;

**Comments:**