



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20131169, Building Permit - Residential

Address: 600 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081600 NW LILAC PL, Unit:C,
LEES SUMMIT, MO 64081600 NW LILAC PL, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Borns	Failed	Thursday, January 16, 2014

Partial Correction
2 MISC

OK TO COVER WHEN READY WALLS AND CEILINGS AT: UNIT "A";

Corrective Action Required
3 MISC

AT UNIT B: IPC 905.2; IRC P3104.2 GRADING OF VENT PIPING TO DRAIN

Gas Piping Inspection - Residential

John Borns	Partial	Thursday, January 16, 2014
------------	---------	----------------------------

Partial Correction
1 MISC

NO ISSUES FOUND ON GAS PIPING MATERIAL AND WORKMANSHIP. GAS PIPING PRESSURE TEST HELD STEADY AT ≥ 10 PSI FOR ≥ 10 MIN. AT UNIT(S): A; B;

CENTRAL METERING. GAS SERVICE RELEASE NOT REQUIRED.

Comments: