



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131453, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Passed	Friday, January 17, 2014

Comments: NO ISSUES FOUND ON PREP TO POUR TRENCH FOOTING FOR DUMPSTER ENCLOSURE AT 36" DEEP x 18" WIDE WITH SINGLE CURTAIN OF #4 RE-BAR. NO DETAIL ON APPROVED DRAWINGS.