



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20132383, Building Permit - Commercial  
Address: 209 SE M 291 HWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Mike Copeland	Failed	Tuesday, January 21, 2014

Corrective Action Required  
1 MISC

- LABEL EXTERIOR DOORS WITH ADDRESS NUMBERS
- RECEPTACLE WITHIN 6 FEET OF SINKS IN MASSAGE ROOMS  
NEED TO BE GFCI PROTECTED
- REAR NORTH DOOR WILL NO SHUT AND LATCH
- FRONT DOOR SHALL HAVE LESS THAN 5 LB.S OF PRESSURE  
TO OPERATE
- SUBMIT BACKFLOW TESTS RESULTS TO WATER UTILITIES  
FOR DOUBLE CHECK VALVES ABOVE CEILING AT WORK  
STATIONS

<b>Above Ceiling Inspection</b>	Mike Copeland	Passed	Tuesday, January 21, 2014
-------------------------------------	---------------	--------	---------------------------

**Comments:**