

Inspection Summary

Permit #: PRCOM20132239, Building Permit - Commercial

Address: 3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|--------------|-----------|-----------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| Underslab Plumbing Inspection - Commercial | Khanh Nguyen | Not Ready | Wednesday, January 22, 2014 |

Corrective Action Required

1 MISC

SOUTH BUILDING DRAIN OF UNIT A&B:

- CANNOT HAVE WASTE STACK TO WET-VENT SHOWER OR WATER CLOSETS
- VERTICAL TO HORIZONTAL CONNECTION MUST BE BY LONG SWEEP OR OTHER APPROVED FITTING FOR 3" OR LARGER
- HAVE PLUMBING REDRAWN FOR CHANGES TO SEWER LOCATION

Comments: