

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20130393  
**Address:** 194 NW OLDHAM PKWY, LEES SUMMIT, MO 64081  
**Inspected On:** Friday, January 24, 2014  
**Inspected By:** John Borns  
**Expiration Date:** 3/27/2014 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Friday, January 24, 2014

**Corrective Action Required:**

1	MISC	FINISH SITEWORK PENDING CONDUCIVE WEATHER. ANITICIPATE LATE MARCH COMPLETION. CALL TO REQUEST RE-INSPECTION WHEN READY.
---	------	---

**Corrective Action Required:**

4	MISC	SECURE ROOFTOP WALKWAY RUNNERS TO PREVENT OBSTRUCTION OF ROOF DRAINS.
---	------	---