



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20132180	Date:	January 27, 2014
Project Title:	SAINT LUKE'S EAST - 5TH FLOOR NORTH INFILL	Applicant:	
Location:	100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086	JAYHAWK FIRE SPRINKLERS	
Type of Work:		10629 SUMMIT STREET	
Occupancy Group:	I-2	LENEXA, KS 66215--2051	
Description:	5TH FLOOR NORTH INFILL	Primary:	(913) 422-3770
Construction Type:	Type IA		
Map Page:	175X		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.