

Inspection Summary

Permit #: PRRES20131169, Building Permit - Residential

Address: 600 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081600 NW LILAC PL, Unit:C, LEES SUMMIT, MO 64081600 NW LILAC PL, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Borns	Passed	Tuesday, January 28, 2014

Comments: OK TO COVER WHEN READY WALLS AND CEILINGS AT: UNIT "A"; UNIT "B"; UNIT "C". ON FUTURE ALL-ROUGH INSPECTIONS PROVIDE LISTING CERTIFICATION FOR STUD SHOES UTILIZED.