

## Inspection Summary

Permit #: PRCOM20140046, Building Permit - Commercial

Address: 198 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Electrical Inspection - Commercial</b>	John Borns	Failed	Friday, January 31, 2014

Corrective Action Required

1 MISC

**ADDRESS LABELING OF ELECTRICAL SERVICE METER/DISCONNECT: APPLY  
PERMANENT ADDRESS STICKER FACING STREET OF ADDRESS.**

<b>Electrical Service Inspection - Commercial</b>	John Borns	Passed	Friday, January 31, 2014
---	------------	--------	--------------------------

**Comments:**