

Temporary Certificate of Occupancy

Permit #: PRCOM20131231
Address: 2151 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064
Inspected On: Friday, February 07, 2014
Inspected By: Khanh Nguyen
Expiration Date: 3/7/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, February 07, 2014

Corrective Action Required:

2 MISC ROOFTOP:
- DESIGNATE RTU'S AND REFLECT @ ELECT PANEL
- PAINT GAS PIPING
- CLEAR/CLEAN ROOF OF MATERIAL & DEBRIS

****CHECK LATER WHEN CONDITION PERMIT**

Corrective Action Required:

3 MISC RESOLVE FIRE DEPT ISSUES

Corrective Action Required:

4 MISC RESOLVE PLANNING & DEVELOPMENT ISSUES

Corrective Action Required:

5 MISC RESOLVE PUBLIC WORKS ISSUE