



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20132462	Date:	February 10, 2014
Project Title:	LEES SUMMIT MEDICAL CENTER	Applicant:	
	VASCULAR LAB		
Location:	2000 SE BLUE PKWY, LEES SUMMIT, MO 64063	Siemens Industry, Inc. 8066 Flint Street Lenexa , KS 66214	
Type of Work:			
Occupancy Group:	B	Primary:	<NO PRIMARY PHONE>
Description:	REMODEL		
Construction Type:	Type IIB (Unprotected)		
Map Page:	196K		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule alarm testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.