

Inspection Summary

Permit #: PRRES20131163, Building Permit - Residential

Address: 610 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081610 NW REDBUD DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	John Borns	Partial	Monday, February 10, 2014

Partial Correction

1 MISC

OK TO COVER WHEN READY WATER SERVICE LINE INSTALLATION FROM BOTH BUILDING ENTRIES TO NEAR METER LOCATION. FOOTING DRAIN DAMAGED AT UNIT "A" TO BE REPAIRED.

Sewer Service Inspection - Residential	John Borns	Passed	Monday, February 10, 2014
---	------------	--------	---------------------------

Comments: