

Inspection Summary

Permit #: PRCOM20132419, Building Permit - Commercial
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|----------------------------|
| Underslab Plumbing Inspection - Commercial | Mike Copeland | Partial | Tuesday, February 18, 2014 |

Partial Correction
1 MISC

-AREAS APPROVED TO COVER EXCEPT THE FOLLOWING:
BATH GROUP NORTH SIDE OF SANITARY LINE AT WEST SIDE OF BUILDING.
ALL TRENCH DRAINS YET TO BE INSTALLED.
TIE IN AT SE AREA OF THE BUILDING

Comments: