

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132712, Building Permit - Commercial
Address: 208 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Friday, February 21, 2014

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT
FOLLOWING SPACES: SPACES #3-7 AFTER CRIPPLE STUDS ABOVE DOORS ARE
FULLY SCREWED AT CONNECTIONS;

Comments: