



PUBLIC WORKS ENGINEERING DIVISION

Punch List

Date: Friday, March 07, 2014

To: Paul Tharp

Re: Certificate of Substantial Completion for:

Chipman Road Animal Clinic

Public Works Infrastructure Permit - Commercial, Development-Complete

PRPWFC20120295

A comprehensive inspection was completed for this project. It has been determined by Public Works that a Certificate of Substantial Completion can be released. The following items were incomplete as of the date of this letter. The developer, contractors and engineers have ninety (90) days to complete these deficiencies in accordance with the City of Lee's Summit's, Design and Construction Manual, Ordinance 5813. All items on this list must be completed before Final Acceptance will be issued.

PUNCH LIST CORRECTIONS:

Install surface layer of asphalt over north side parking area. **(Must be completed within 30 days from the date of this letter)**

Install striping on surface layer of asphalt on north side parking area. **(Must be completed within 40 days from the date of this letter)**

Establish vegetation and maintain erosion control on all areas disturbed by construction.

, Developer
(Signature & Date)

Bob Burns, Public Works Inspector
(Signature & Date)

Original: Public Works Inspections File

Copy:

Developer

Public Works Development Engineering Manager

Contractor

Design Engineer / Architect