

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Friday, March 07, 2014

Partial Correction
1 MISC

FOLLOWING AREA(S) OK FOR USE & OCCUPANCY: AREA "B";

REMAINDER OF AREAS A & B OK TO SET UP FOR BUSINESS. NOT READY FOR FULL INSPECTION FOR OCCUPANCY. NO OPERATION PRIOR TO APPROVAL.

Alarm Test	Joe Dir	Passed	Friday, March 07, 2014
-------------------	---------	--------	------------------------

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Friday, March 07, 2014
--	---------	------------------	------------------------

Corrective Action Required
1 MISC

- sprinkler room doors interior and exterior, label the doors "sprinkler room"
- label the sprinkler risers with coverage areas
- elevators need to meet state specifications, need a copy of the state certification
- label the warning strobe in the control room CO SENSOR
- install strobes in the main level training area restrooms
- install a smoke detector above the main fire alarm panel
- test the CO sensor in the C-area garage
- uncover all exit signs main level training area
- emergency lighting throughout lower level not working
- adjust the rate of fall on all roll down doors
- temp/lighting still in place in A-106 area
- door E117B needs to unlock on a alarm activation
- paint the bonnet silver of all private hydrants.

Comments: