

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20132531, Building Permit - Residential  
Address: 1629 NE SHADOW VALLEY DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|   |              |          |                           |
|---|--------------|----------|---------------------------|
| Inspection:                             | Inspector:   | Outcome: | Date:                     |
| <b>Pool Steel/Bonding - Residential</b> | Khanh Nguyen | Partial  | Wednesday, March 12, 2014 |

Corrective Action Required

1 MISC

THE FOLLOWINGS ARE BONDED:  
-POOL METAL SHELL, LIGHT NICHE

\*\*SHALL USE LISTED REBAR BONDING/GROUNDING CLAMPS  
\*\*EXPOSE THE BONDING CONDUCTOR TO BOND THE POOL COVER MOTOR & FRAME  
\*\*UNDERGROUND CONDUCTORS SHALL BE LISTED FOR WET LOCATION.  
CANNOT USE NM CABLE

Comments: