

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20132531, Building Permit - Residential
Address: 1629 NE SHADOW VALLEY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Passed	Wednesday, March 12, 2014

Comments:

THE FOLLOWINGS ARE BONDED:

-POOL METAL SHELL, LIGHT NICHE, DECK REBAR, LADDER AND HANDRAIL BASES

**UNDERGROUND CONDUCTORS SHALL BE LISTED FOR WET LOCATION. CANNOT USE NM CABLE.
CHECK ON FINAL