

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20131937, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Not Ready	Wednesday, March 12, 2014

Partial Correction

1	MISC	FIRE DEPARTMENT ISSUES: NONE REMAINING
Corrective Action Required		
2	MISC	WATER DEPARTMENT ISSUES: TO BE RESOLVED
Corrective Action Required		
3	MISC	PUBLIC WORKS ISSUES: REMAINING SITEWORK SUBJECT TO APPROVAL
Corrective Action Required		
4	MISC	PLANNING DEPARTMENT INSPECTION PENDING COMPLETION OF SITEWORK
Corrective Action Required		
5	MISC	ROOFTOP INSPECTION: - NUMBER OR LETTER RTU'S; REFLECT AT E-PANEL - PROTECT LOW VOLTAGE WIRING @ EAST WALL - COMPLETE PAINTING GAS PIPING - CLEAR/CLEAN ROOF SURFACE -- ALL MATERIAL
Corrective Action Required		
6	MISC	DESIGNATE TWO ELECT SERVICE DISCONNECTS OUTSIDE BUILDING; DESIGNATE TWO E-PANELS INSIDE.
Corrective Action Required		
7	MISC	ALL EXTERIOR WORK SUBJECT TO APPROVAL WHEN COMPLETED
Corrective Action Required		
8	MISC	OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. NO PATIENTS NOR PUBLIC PRIOR TO APPROVAL.

Occupancy Inspection - Brian Austerman Passed
Fire

Wednesday, March 12, 2014

Comments:

