

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132712, Building Permit - Commercial
Address: 208 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, March 13, 2014

Partial Correction

1 MISC

OK TO COVER WHEN READY WALL FRAMING + IN-WALL SYSTEMS AT
FOLLOWING SPACES: SPACES #3-7;

SPACE 10 OK TO ONE-SIDE ONLY

**IN-WALL SYSTEMS AT SPACES 8,9,10 TO BE REQUESTED FOR FULL IN-WALL
INSPECTION AFTER ALL WORK INCLUDING REMOVAL OF ABANDONED
CONCEALED ELECTRICAL WIRING IS COMPLETED. PLUMBING ONLY IS
PRESENTLY APPROVED.**

Comments: