

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20131167, Building Permit - Residential

Address: 622 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081622 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081622 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	John Borns	Passed	Friday, March 14, 2014

Comments: GAS PIPING PRESSURE TEST HELD STEADY AT ≥ 10 PSI FOR ≥ 10 MIN. VISUAL INSPECTION OF PIPING INSTALLATION IN CRAWL SPACE WILL BE PERFORMED AT OR BEFORE FINAL INSPECTION.