

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132239, Building Permit - Commercial
Address: 3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	Khanh Nguyen	Partial	Monday, March 17, 2014

Partial Correction
1 MISC

-UNDERSLAB ELECTRICAL APPROVED FROM ELEVATOR TO THE WEST
-FROM NORTH OF BUILDING TO CONTROL JOINT
-2" RACEWAY TO 2ND FL HOUSE PANEL

Comments: