

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140176, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:C, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Not Ready	Tuesday, March 18, 2014

Corrective Action Required

1	MISC	SOME UNDER-SLAB DWV PIPING NOT PER APPROVED DRAWING. DO NOT COVER.
---	------	---

In-wall Inspection	John Borns	Partial	Tuesday, March 18, 2014
---------------------------	------------	---------	-------------------------

Partial Correction

1	MISC	OK TO COVER EHEN READY WALL FRAMING & IN-WALL SYSTEMS AT: DEMISING WALLS AT SOUTH & NORTH INTERIOR ELEVATIONS;
---	------	---

Comments: