



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20140176	Date:	March 18, 2014
Project Title:	CHARLOTTE RUSSE	Applicant:	
Location:	880 NW BLUE PKWY, Unit:C, LEES SUMMIT, MO 64086	KCFS	
Type of Work:		901 E LOULA	
Occupancy Group:	M	OLATHE, KS 66061	
Description:	TENANT FINISH FOR CLOTHING STORE	Primary:	<NO PRIMARY PHONE>
Construction Type:	Type IIB (Unprotected)		
Map Page:	195A		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Horn strobes in restrooms to be switched to strobes only

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.