

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20131453, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Failed	Wednesday, March 19, 2014

Corrective Action Required

1 MISC

LIGHT POLE BASES: VERTICAL RE-BAR NOT #7 PER DRAWING. GROUNDING CONDUCTOR NOT CAD-WELDED TO ROD PER DRAWING.

Comments: